## AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

						1. PAGE	1 OF 2 PAGES	
2. AM ENDM	ENT/MODIFICATION NO.:	3. EFFECTIVE			5A. SOLICITATION/CONTRACT/PR	OJECT TITLE	3	
		DATE	REQUISITI	ON NO.:	House Office Building Fire Protection System Inspection & Testing			
	04	4 09/13/2006			5B. PROJECT NO (Ifapplicable)			
6. ISSUED BY  ARCHITECT OF THE CAPITOL  United States Capitol  Washington, D.C. 20515				7. ADDRESS AMENDMENT/MODIFICATION TO Architect of the Capitol Procurement Division Ford House Office Building, Room H2-263 Attn: (Ryan Kirkwood) Second and "D" Streets, S.W. Washington, DC 20515				
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)					9A. AMENDMENT OF SOLICITATION NO. RFP060131			
				(X)	9B. DATED (See Item 11) 08/16/2006			
					10A. MODIFICATION OF CONTRACT/ORDER NO.			
					10B. DATED (See Item 13)			
	11. TH	IS ITEM APPLI	ES ONLY TO	AMEND	MENTS OF SOLICITATIONS			
12. ACCOUN	NTING AND APPROPRIATION DATA	(If required)						
					ONS OF CONTRACTS/ORDERS A AS DESCRIBED IN ITEM 14.	ND		
Check One	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.							
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)(1)							
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
	D. OTHER (Specify type of modification and authority)							
E. IMPORTA	NT: Contractor is not, is re	equired to sign this d	ocument and return	it to the is	ssuing office.			
14. DESCRI	PTION OF AMENDMENT/MODIFICAT	ION						
	f this amendment is to answer bidders que NTINUATION PAGE	estions.						
Except as prov	vided herein, all terms and conditions of the	e document referenc	eed in Item 9A or 1	0A, as here	etofore changed, remains unchanged and in	full force and e	effect.	
15A. NAME	AND TITLE OF SIGNER (Type or print)			16A. N	AME OF CONTRACTING OFFICER (Ty	pe or print)		
15B. OFFEROR/CONTRACTOR 15C. DATE SIGNE			DATE SIGNED		NITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)			Ву	(Signature of Contracting Officer)				

AOC 30 July 2004 AMENDMENT NO.: 04 Solicitation No.: RFP060131

This amendment is issued as follows: (The purpose of this amendment is to answer bidders questions).

Q: Is the scope of this bid the same scope as the previous contract, where it requires after hours fire alarm testing?

Answer: The scope is essentially the same with a few minor adds/deletions.

Q: Were the fire extinguishers included in the previous contract?

Answer: It appears that the fire extinguishers were only included in the base year of the previous contract.

Q: Were all (6) buildings included?

Answer: Yes

Q: Was fire pump and dry pipe testing required to be done after hours?

Answer: Dry pipe was required to be done after hours. Fire pumps are typically done on a Saturday.

Distribution:

Contract File